

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0694:231 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Fire Control Instruments, *16 Southwest Park, Westwood MA 02090
Contact: Anthony J. Shalna (781) 471-3000 FAX (781) 471-3099

DESIGN: Model LCD-7100 remote serial annunciator. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as remote annunciator for use with separately listed model 7100 fire alarm control unit (CSFM Listing No. 7165-0494:219).

*Rev. 02-05-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

FEBRUARY 5, 2004

Listing Expires June 30, 2004

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager